



# STEGE SANITARY DISTRICT STAFF REPORT

Board of Directors Meeting Date: 7/2/2026

---

**TO:** Honorable Board of Directors  
**FROM:** Dennis Wright, Maintenance Superintendent  
**SUBJECT:** Superintendent's Reports

---

## RECOMMENDATION

It is recommended that the Board of Directors Receive and File the Superintendent's Reports.

## BACKGROUND AND DISCUSSION

Staff provides several monthly reports related to the District's operations. For the month of May 2026, the following reports have been included:

- Verbal Maintenance Report
- Maintenance Summary Report
- Service Call Report
- Sanitary Sewer Overflow Report

## FISCAL IMPACT

There is no fiscal impact to receiving and filing the reports.

# STEGE SANITARY DISTRICT MONTHLY MAINTENANCE SUMMARY REPORT

## May 2026

QUARTER 2

VEHICLE	DAYS	FOOTAGE (LF)
<i>UNIT 10 COMBO</i>	5	17,967
<i>UNIT 11 RODDER</i>	0	
<i>UNIT 15 CCTV</i>	3	3,368
<i>UNIT 16 COMBO</i>	14	43,337
<b>TOTAL MONTH CLEANED</b>		<b>61,304</b>
<b>TOTAL MONTH CCTV'D</b>		<b>3,368</b>

### QUARTERLY SUB-TOTALS

YEAR	QTR	PLANNED TO CLEAN (LF)	TOTAL CLEANED (LF)	Q END NOT COMPLT'D (LF)	PLANNED TO CCTV (LF)	TOTAL CCTV'D (Plan)	Q END NOT COMPLT'D (LF)	TOTAL CCTV'D (Unplan)	TOTAL CCTV'D (LF)
<b>2026</b>	<b>2</b>	248,778	145,523	106,478	38,545	15,863	22,682	3,770	19,633
<b>2026</b>	<b>1</b>	305,065	275,623	33,306	38,784	38,656	128	15,342	53,998
<b>2025</b>	<b>4</b>	252,627	199,444	41,777	28,724	27,299	1,425	12,171	39,470
<b>2025</b>	<b>3</b>	264,479	216,621	47,205	34,083	33,349	734	14,810	48,159
<b>2025</b>	<b>2</b>	225,530	226,508	0	14,607	14,607	0	21,619	36,226
<b>2025</b>	<b>1</b>	253,405	260,805	0	43,453	41,192	2,261	30,164	71,356

# MONTHLY SERVICE CALLS

# May-2026

DATE	MH UP/DN	ADDRESS	PRBLM IN	TYPE	LOC	CAUSE	END	COMMENTS
5/2/2026 Saturday 9:55 AM	283034 283033	1007 KING DR. EL CERRITO, CA 94530	Main <input type="checkbox"/> Lateral <input checked="" type="checkbox"/> Other <input type="checkbox"/>	C				CUSTOMER PROBLEM. AVE SEWER MAIN LINE IS CLEAR. MAP PAGE 20.
5/4/2026 Monday 9:50 AM	161912 162017	6910 GLADYS AVE. EL CERRITO, CA 94530	Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other <input checked="" type="checkbox"/>	O				CUSTOMER PROBLEM, WANTED US TO SHOW UP AFTER 12PM. MAP PAGE 13.
5/11/2026 Monday 9:50 AM	265800 265700	921 ARLINGTON AVE. EL CERRITO, CA 94530	Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other <input checked="" type="checkbox"/>	MC				NOISY MANHOLE COVER. COULD NOT LOCATE. MAP PAGE 20.
5/14/2026 Thursday 10:00 AM	172309 172308	2016 MIRA VISTA DR. EL CERRITO, CA 94530	Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other <input checked="" type="checkbox"/>	C				CUSTOMER PROBLEM. MAP PAGE 9.
5/19/2026 Tuesday 9:30 AM	161507 161506	1810 KEY BLVD. EL CERRITO, CA 94530 <i>Last Call: 1/3/2002</i>	Main <input type="checkbox"/> Lateral <input checked="" type="checkbox"/> Other <input type="checkbox"/>	LC				CUSTOMER PROBLEM. MAP PAGE 9

**PROBLEM TYPE:**

- Water (A)
- Broken Main (B)
- S/S Congestion (C)
- Debris in Main (D)
- EBMUD (E)
- Soft Stoppage (F)
- Grease (G)
- Lateral Cause (LC)
- Misc (M)
- MH Cover (MC)
- Odor (O)
- Overflow (OF)
- PG+E (P)
- Roots (R)
- Surcharge (S)
- Storm Drain (SD)
- Unknown (U)
- Other (T)
- Wipes/Rags (W)

**SPILL**

- LOCATION:**
- Lamp/Manhole (MH)
  - Mainline (ML)
  - Lateral (L)
  - Cleanout (CO)
  - Building (BLDG)
  - Other (O)

**SPILL**

- CAUSE:**
- Blockage (B)
  - Surcharge (S)
  - Line Break (ML)
  - Other (O)

**SPILL END**

- LOCATION:**
- Building (BLDG)
  - Creek (C)
  - Strt/Pvmnt (ST)
  - Storm Dm (SD)
  - Yard (Y)
  - Other (O)

<b>MAINLINE:</b>	<b>0</b>
<b>LATERAL:</b>	<b>2</b>
<b>OTHER:</b>	<b>3</b>
<b>TOTAL SERVICE CALLS:</b>	<b>5</b>
<b>MAINLINE OVERFLOW:</b>	<b>0</b>
<b>MAINLINE SURCHARGE:</b>	<b>0</b>

# SANITARY SEWER OVERFLOWS (SSOs) LAST 12 MONTHS

## June-2026

DATE	MH UP/DN	ADDRESS	PRBLM IN	TYPE	LOC	CAUSE	END	COMMENTS	CAT*	VOL	RCVR'D	NET
7/7/2025	186230	7075 CUTTING BLVD.	<input checked="" type="checkbox"/> Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other	B,OF,T	CO	ML,B	ST	UTILITY DAMAGED SEWER LINE CAUSING SSO. ATT DIRECTIONALLY DRILLED THROUGH LINE.	CAT 4	2	0	2
Monday	186212	EL CERRITO, CA 94530								gallons	gallons	gallons
11:22 AM												
10/21/2025	151005	1440 NAVELLIER ST.	<input checked="" type="checkbox"/> Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other	D,OF,R	MH	B	O	ROOTS AND STICKS CAUSED SSO ON NAVELLIER TRAIL	CAT 3	835	835	0
Tuesday	151004	EL CERRITO, CA 94530								gallons	gallons	gallons
9:43 AM												
4/13/2026	103303	2323 COLUMBIA AVE.	<input checked="" type="checkbox"/> Main <input type="checkbox"/> Lateral <input type="checkbox"/> Other	D,OF	MH	B	ST	CONCRETE AND STEEL WOOL IN LINE CAUSED SSO	CAT 3	355	106	249
Monday	103302	RICHMOND, CA 94804								gallons	gallons	gallons
8:56 AM												

PROBLEM TYPE:	SPILL CAUSE:	SPILL LOCATION:	SPILL END LOCATION:	TOTAL MAINLINE SSOs:
Water (A)	Odor (O)	Lamp/Manhole (MH)	Building (BLDG)	3
Broken Main (B)	Overflow (OF)	Mainline (ML)	Creek (C)	1
S/S Congestion (C)	PG+E (P)	Lateral (L)	Strt/Pymnt (ST)	0
Debris in Main (D)	Roots (R)	Cleanout (CO)	Storm Dm (SD)	0
EBMUD (E)	Surcharge (S)	Building (BLDG)	Other (O)	0
Soft Stoppage (F)	Storm Drain (SD)	Other (O)	Other (O)	0
Grease (G)	Unknown (U)			
Lateral Cause (LC)	Other (T)			
Misc (M)	Wipes/Rags (W)			
MH Cover (MC)				
				TOTAL SSO VOLUME (GALS): 1,192
				TOTAL VOLUME RECOVERED (GALS): 941
				TOTAL VOLUME UNRECOVERED (GALS): 251

\*CATEGORY 1 SSO: Spill of any volume of sewage from or caused by a sanitary sewer system that results in a discharge to: A surface water, including a surface water body that contains no flow or volume of water; or A drainage conveyance system that discharges to surface waters when the sewage is not fully captured and returned to the sanitary sewer system or disposed of properly. Any spill volume not recovered from a drainage conveyance system is considered a discharge to surface water, unless the drainage conveyance system discharges to a dedicated stormwater infiltration basin or facility.

CATEGORY 2 SSO: Spill of 1,000 gallons or greater, from or caused by a sanitary sewer system that does not discharge to a surface water.

CATEGORY 3 SSO: Spill of equal to or greater than 50 gallons and less than 1,000 gallons, from or caused by a sanitary sewer system that does not discharge to a surface water.

CATEGORY 4 SSO: Spill of less than 50 gallons, from or caused by a sanitary sewer system that does not discharge to a surface water.